



防 爆 合 格 证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号
Certificate No. CE21. 3077

产 品 名 称

Name of Product

型 号 及 规 格

Type of Product

防 爆 标 志

Marking

技 术 文 件

Technical Documents

图 号

Drawing No.

备 注

Note (s)

电源隔离式安全栅

GST-LD-N8402 (Ex)

海湾安全技术有限公司

Ex ib Gb IIC

303050958617

Q/GST 55-2019、Q/GST 205.3-2016

F2. 909. 1341、F2. 909. 1413

1. 安全栅参数: U_m : 250VAC/DC,
 U_o : 28V, I_o : 115mA, C_o : 0.083uF, L_o : 0.45mH, P_o : 0.8W.
2. 产品使用环境温度: $-10^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$.

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010 GB 3836.4-2010

发 给: 海湾安全技术有限公司
Issued to:

本证失效日期: 2026-12-01

Date of Expire:

发 证 日 期: 2021-12-01

Date of Issue:

中心印章
Center seal中心主任
Director

刘红光

国 家 防 爆 产 品 质 量 检 验 检 测 中 心 (天 津)
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Product Quality Inspection and Testing Center (Tianjin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail: pcec@pcec.com.cn

邮政编码: 300131

电话/传真: 022-26651066/26689116

Tel/ Fax: 022-26651066/26689116

http://www.pcec.com.cn